
CHEVRON RICHMOND P6 PUMP AT 21 PUMP STATION



P6 Pump prepped




"V" out crack damage ready to accept bronze.

Crack damage before prep work is done to the crack.




Pump positioned to be Furnace Brazed



Oven built for Pump and ready for Pre-Heat



1200 degree pre-heat



Furnace brazing in process

With the part pre heated to 1200 degrees the bronze will melt at 1800 degrees. You can see Alaa using Acetylene torch to melt the bronze



Post Weld



After hand finishing the repair



Machined Flange




Machined flange ready for assembly

The repair on the cracked flange is - complete.

Additional damage discovered



Additional repairs completed



Getting ready for Hydro Testing



Hydro Test Report

On 2-29-12 Hydro test was done by Alaa Al'Robaie, Brian Schoppet of *LOCK-N-STITCH* Inc. and Rob Wieben of Chevron, Richmond, CA.

Hydro test was done at 400 psi for a duration of one (1) hour. No leaks where present during this time.

The test was verified by Rob Wieben on 2-29-12

Scope of work

The filer metal is standard low fuming bronze rod.

NOMINAL CHEMICAL COMPOSITION:

Copper 58-62 % Zinc Balance Tin .30-3.00 % Manganese .25 % max Iron 1.50 % max Silicon .30 % max Aluminum .01 % max. Lead .05 % max.

PHYSICAL PROPERTIES:

Melting Point 1620° F (882° C) Working Temperature 1600-1720° F(871-938° C) Tensile Strength 60,000-65,000 psi Brinell hardness 80-90 Machinability Excellent

We have been using this process for over 40 years with 100% success. The part is pre-heated to 1100-1200°F until the entire casting temperature is uniform. While in the oven it is brazed with an acetylene torch. This requires heating the area to be brazed to 1750°F. The part is not removed from the oven during the brazing process.

After the brazing is completed the part is kept in the oven for about 15 minutes and allowed to stay in the oven overnight or until it reaches 200°F.

We do this process just about every day.